



Construction Notes:

FPL Contractor to install 2in PVC with 24in minimum cover and hand holes for all locations. Call locates prior to digging. Loc. 1-8: FPL contractor to install 21ft Black Tapered Concrete Pole and GE, PTT 39Watts, 3000K Fixture (With side panels). Connect to existing service using directional bore. Verify fixture is working correctly after installation. Check 120V to terminal blocks.

'CHECK VOLTAGE – CONVERT 480V to 120V or 240V' On 480V circuits, change the relay prior to installing the lights. Verify the source and amount of lights on that relay. Contact the FPL PL to assist with this process.

-FPL crew to run #6 DPX UG cable to all locations shown in the drawing.

-All facilities to be installed within utility easement.

-Customer to contact FPL PL and coordinate staking of all locations prior LED installations. Customer is responsible for any restoration required.

FPL LED Representative: Jamie Young

**GE, Traditional
Carriage, 73W, 3000K
(With Side Panels)**



17" HANDHOLE

TYPICAL INSTALLATION

AS-BUILT CREW PRINT				<small>ALL REQUIRED GRID COORDINATES HAVE BEEN DRAWN & VERIFIED TO BE WITHIN FPL STANDARDS, VALUES ARE SHOWN AT ALL LOCATIONS.</small>				<small>JOB CERTIFIED COMPLETE DASH SHOWN ON THIS AS-BUILT PRINT. MATERIAL CHANGES SHOWN ON RDS</small>				AS-BUILT COPY			
FOREMAN'S SIGNATURE _____ DATE _____				FOREMAN'S SIGNATURE _____ DATE _____				SUPERVISOR'S SIGNATURE _____ DATE _____				INITIALS _____ CERT. DATE _____			
Easement? Yes <input checked="" type="checkbox"/> No <input type="checkbox"/>				Survey/Stake? Yes <input checked="" type="checkbox"/> No <input type="checkbox"/>				Work with SMO? Yes <input type="checkbox"/> No <input checked="" type="checkbox"/>				<div style="border: 1px solid black; padding: 5px; text-align: center;"> FPL </div> <div style="text-align: center; padding: 10px;"> Vanderbilt Lakes - Full Conv. Install 18 New Lights & Poles V/O 3621 Saybrook Pl, Bonita Springs, FL 34134 </div>			
Tree Work? Yes <input type="checkbox"/> No <input checked="" type="checkbox"/>				Designer/Stake? Yes <input type="checkbox"/> No <input checked="" type="checkbox"/>				CT/Special Mtr? Yes <input type="checkbox"/> No <input checked="" type="checkbox"/>							
PERMIT REQ'D	City WMD	County Rd. RR Xing	County Air DR. Dist.	State Road Transm.	FAA	<div style="display: flex; justify-content: space-between;"> <div> Designed by: Jorge H Cruz Gotay Drawn by: JCG Check by: _____ Rural Location Sec. XX TWP. XX S, RGE. XX E. </div> <div> Date: 05/25/22 Dwg No. 1 OF 3 </div> </div>									
Requested Tel. Co. Set Poles ? YES <input type="checkbox"/> NO <input checked="" type="checkbox"/>														Telephone Co., Job No. _____	
Requested Tel. Co. Transfer ? YES <input type="checkbox"/> NO <input checked="" type="checkbox"/>															
Request CAVT Transfer? YES <input type="checkbox"/> NO <input checked="" type="checkbox"/>															
POLE LINE FEET 0'				DUCT BANK FT. 0'											
POLE LINE FT. ON TRANSM. POLES 0'				TRENCH FT. 0'				SCALE: N.T.S. St. Lt MAP No. MAP# Pri Map No. XXXXX							
TLM/LDS MODEL No. -		Map Posting? YES <input checked="" type="checkbox"/> NO <input type="checkbox"/>		Posted by:		WR XXXXXXXX M/A XX									



☐ INACCESSIBLE

☒ 13 kV

☐ FUTURE 23 kV

☐ 23 kV

☐ SALT SPRAY



**GE, Traditional
Carriage, 73W, 3000K
(With Side Panels)**



**21ft Black
Tapered
Concrete
Pole**

17" HANDHOLE

TYPICAL INSTALLATION

Construction Notes:

- FPL Contractor to install 2in PVC with 24in minimum cover and hand holes for all locations. Call locates prior to digging.
- Loc. 9-13: FPL contractor to install 21ft Black Tapered Concrete Pole and GE, PTT 39Watts, 3000K Fixture (With side panels). Connect to existing service using directional bore. Verify fixture is working correctly after installation. Check 120V to terminal blocks.
- ‘CHECK VOLTAGE – CONVERT 480V to 120V or 240V’ On 480V circuits, change the relay prior to installing the lights. Verify the source and amount of lights on that relay. Contact the FPL PL to assist with this process.
- FPL crew to run #6 DPX UG cable to all locations shown in the drawing.
- All facilities to be installed within utility easement.
- Customer to contact FPL PL and coordinate staking of all locations prior LED installations. Customer is responsible for any restoration required.

FPL LED Representative: Jamie Young

AS-BUILT CREW PRINT				ALL REQUIRED GROUND RODS HAVE BEEN DRAWN & VERIFIED TO BE WITHIN FL STANDARDS, VALUES ARE SHOWN AT ALL LOCATIONS.				JOB CERTIFIED COMPLETE & AS SHOWN ON THIS AS-BUILT PRINT. MATERIAL CHANGES SHOWN ON RODS				AS-BUILT COPY																			
FOREMAN'S SIGNATURE _____				DATE _____				FOREMAN'S SIGNATURE _____				DATE _____				SUPERVISOR'S SIGNATURE _____				DATE _____				INITIALS _____				CERT. DATE _____			
Easement? Yes <input checked="" type="checkbox"/> No <input type="checkbox"/>				Survey/Stake? Yes <input checked="" type="checkbox"/> No <input type="checkbox"/>				Work with SMO? Yes <input type="checkbox"/> No <input checked="" type="checkbox"/>				FPL				Vanderbilt Lakes - Full Conv. Install 18 New Lights & Poles V/O 3621 Saybrook Pl, Bonita Springs, FL 34134															
Tree Work? Yes <input type="checkbox"/> No <input checked="" type="checkbox"/>				Designer/Stake? Yes <input type="checkbox"/> No <input checked="" type="checkbox"/>				CT/Special Mtr? Yes <input type="checkbox"/> No <input checked="" type="checkbox"/>																							
PERMIT REQ'D				City				County Rd.				County Air												State Road				FAA			
WMD				RR Xing				DR. Dist.				Transm.																			
Requested Tel. Co. Set Poles ?				YES <input type="checkbox"/> NO <input checked="" type="checkbox"/>				Tele. Attachment Per				Designed by: Jorge H Cruz Gotay				Date: 05/25/22															
Requested Tel. Co. Transfer ?				YES <input type="checkbox"/> NO <input checked="" type="checkbox"/>								Drawn by: JCG				Check by:				Dwg No. 2 OF 3											
Request CAVT Transfer?				YES <input type="checkbox"/> NO <input checked="" type="checkbox"/>				Telephone Co. Job No.				Rural Location Sec. XX				TWP. XX				S. RGE. XX				E. XX							
POLE LINE FEET				0'				DUCT BANK FT.				0'				SCALE: N.T.S				St. Lt MAP No. MAP#				Pri Map No. XXXXX							
POLE LINE FT. ON TRANSM. POLES				0'				TRENCH FT.				0'				WR				XXXXXXX				M/A				XX			
TLM/LDS MODEL No.				-				Map Posting? YES <input checked="" type="checkbox"/> NO <input type="checkbox"/>				Posted by:																			



☐ INACCESSIBLE

☒ 13 kV

☐ FUTURE 23 kV

☐ 23 kV

☐ SALT SPRAY



**GE, Traditional
Carriage, 73W, 3000K
(With Side Panels)**



**21ft Black
Tapered
Concrete
Pole**

17" HANDHOLE

TYPICAL INSTALLATION

Construction Notes:

FPL Contractor to install 2in PVC with 24in minimum cover and hand holes for all locations. Call locates prior to digging.

Loc. 14-18: FPL contractor to install 21ft Black Tapered Concrete Pole and GE, PTT 39Watts, 3000K Fixture (With side panels). Connect to existing service using directional bore. Verify fixture is working correctly after installation. Check 120V to terminal blocks.

‘CHECK VOLTAGE – CONVERT 480V to 120V or 240V’ On 480V circuits, change the relay prior to installing the lights. Verify the source and amount of lights on that relay. Contact the FPL PL to assist with this process.

-FPL crew to run #6 DPX UG cable to all locations shown in the drawing.

-All facilities to be installed within utility easement.

-Customer to contact FPL PL and coordinate staking of all locations prior LED installations. Customer is responsible for any restoration required.

FPL LED Representative: Jamie Young

AS-BUILT CREW PRINT		ALL REQUIRED GROUND RODS HAVE BEEN DRAWN & VERIFIED TO BE WITHIN FPL STANDARDS, VALUES ARE SHOWN AT ALL LOCATIONS.		JOB CERTIFIED COMPLETE AS SHOWN ON THIS AS-BUILT PRINT. MATERIAL CHANGES SHOWN ON RODS		AS-BUILT COPY	
FOREMAN'S SIGNATURE _____ DATE _____		FOREMAN'S SIGNATURE _____ DATE _____		SUPERVISOR'S SIGNATURE _____ DATE _____		INITIALS _____ CERT. DATE _____	
Easement? Yes <input checked="" type="checkbox"/> No <input type="checkbox"/>		Survey/Stake? Yes <input checked="" type="checkbox"/> No <input type="checkbox"/>		Work with SMO? Yes <input type="checkbox"/> No <input checked="" type="checkbox"/>		FPL	
Tree Work? Yes <input type="checkbox"/> No <input checked="" type="checkbox"/>		Designer/Stake? Yes <input type="checkbox"/> No <input checked="" type="checkbox"/>		CT/Special Mtr? Yes <input type="checkbox"/> No <input checked="" type="checkbox"/>			
PERMIT REQ'D	City	County Rd.	County Air	State Road	FAA		
	WMD	RR Xing	DR. Dist.	Transm.			
Requested Tel. Co. Set Poles ? YES <input type="checkbox"/> NO <input checked="" type="checkbox"/>		Tele. Attachment Per _____		Designed by: Jorge H Cruz Gotay		Date: 05/25/22	
Requested Tel. Co. Transfer ? YES <input type="checkbox"/> NO <input checked="" type="checkbox"/>		Telephone Co. Job No. _____		Drawn by: JCG		Check by: _____	
Request CAVT Transfer? YES <input type="checkbox"/> NO <input checked="" type="checkbox"/>				Dwg No. 3 OF 3			
POLE LINE FEET 0'		DUCT BANK FT. 0'		Rural Location Sec. XX TWP. XX S, RGE. XX E.			
POLE LINE FT. ON TRANSM. POLES 0'		TRENCH FT. 0'		SCALE: N.T.S		St. Lt MAP No. MAP# Pri Map No. XXXXX	
TLM/LDS MODEL No. -		Map Posting? YES <input checked="" type="checkbox"/> NO <input type="checkbox"/> Posted by: _____		WR XXXXXXXX		M/A XX	